



PUBLIC HEALTH ENGINEERING DEPARTMENT

DISTRICT WATER TESTING LABORATORY, JHAJJAR

Website :- <https://phedharyana.gov.in/>

Memo No:- 2274

Date:- 30/10/2025

Subject : Bacteriological Examination Report of Water Sample

		Sample Details	Date & Time
Sample ID:	JJR/05179/10/2025	Collected By	AMIT YADAV,9812535253
Sample Classification:	Private	Collection Date	15/10/2025 at 15:03
Sender:	PRINCIPAL H.D.SR.SEC.SCHOOL	Received at lab	28/10/2025 at 15:18
Location :-	, VPO-SALHAWAS	Tested at Lab	30/10/2025
Latitude :-	76.466732	Longitude :-	28.454883

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Protocol Used
1	Total Coliform per 100 ml	0	Shall not be detectable in any 100 ml sample	IS 15185:2016/APHA 9223B-2023/APHA 9221C-2023

Remarks :-

- * The Results Given above are related to the sample as received and tested in JHAJJAR lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.

Water Sample has been found "**CONFORMING**" to Limits set in BIS10500:2012 for the tested parameters.
Based on the tested parameters,the water sample is found "**POTABLE**"



SONIA,CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT WATER TESTING LABORATORY,JHAJJAR
email:-chemist.jhajjar@phedharyana.gov.in

-----End of Report-----.

BM
Manager
H.D. Sr. Sec. School
Salhawas (Jhajjar)
Affiliation No-40417
School Code-530430

[Signature]
Principal
H.D. Sr. Sec. School
Salhawas (Jhajjar)
School Code-40417
Affiliation No-530430