

Memo No:- 2274

Date:- 30/10/2025

Subject : Bacteriological Examination Report of Water Sample

Sample ID:	JJR/05179/10/2025	Sample Details	Date & Time
Sample Classification:	Private	Collected By	AMIT YADAV,9812535253
Sender:	PRINCIPAL H.D.SR.SEC.SCHOOL	Collection Date	15/10/2025 at 15:03
Location :-	, VPO-SALHAWAS	Received at lab	28/10/2025 at 15:18
Latitude :-	76.466732	Longitude :-	28.454883
		Tested at Lab	30/10/2025

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Protocol Used
1	Total Coliform per 100 ml	0	Shall not be detectable in any 100 ml sample	IS 15185:2016/APHA 9223B-2023/APHA 9221C-2023

Remarks :-

- * The Results Given above are related to the sample as received and tested in JHAJJAR lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.

Water Sample has been found "**CONFORMING**" to Limits set in BIS10500:2012 for the tested parameters. Based on the tested parameters,the water sample is found "**POTABLE**"



SONIA,CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT WATER TESTING LABORATORY,JHAJJAR
email:-chemist.jhajjar@phedharyana.gov.in

-----End of Report-----.